

High-current terminal block - PTPOWER 95-F - 3260133

Please be informed that the data shown in this PDF Document is generated from our Online Catalog. Please find the complete data in the user's documentation. Our General Terms of Use for Downloads are valid (<http://phoenixcontact.com/download>)



High-current terminal block, Connection method: Push-in connection, Cross section: 25 mm² - 95 mm², AWG: 4 - 3/0, Width: 25 mm, Height: 99.8 mm, Color: gray, Mounting type: ct screw connection

Product Features

- ✓ Quick and easy connection is now also possible for large conductors with the high-current terminal block
- ✓ The Push-in connection terminal blocks are characterized by the system features of the CLIPLINE complete system and by easy and tool-free wiring of conductors with ferrules or solid conductors
- ✓ The compact design enables wiring in a confined space
- ✓ In addition to using the existing test connection, pick-off terminal blocks can be connected, each of which can also accommodate two test cables
- ✓ Tested for railway applications



Key commercial data

| | |
|--------------------------------------|-----------|
| Packing unit | 1 pc |
| Minimum order quantity | 10 pc |
| Weight per Piece (excluding packing) | 204.0 GRM |
| Custom tariff number | 85369010 |
| Country of origin | Poland |

Technical data

General

| | |
|---|------------------------|
| Number of levels | 1 |
| Number of connections | 2 |
| Color | gray |
| Insulating material | PA |
| Inflammability class according to UL 94 | V0 |
| Area of application | Railway industry |
| | Mechanical engineering |
| | Plant engineering |

High-current terminal block - PTPOWER 95-F - 3260133

Technical data

General

| | |
|---|---|
| Maximum load current | 232 A (with 95 mm ² conductor cross section) |
| Rated surge voltage | 8 kV |
| Pollution degree | 3 |
| Surge voltage category | III |
| Insulating material group | I |
| Connection in acc. with standard | IEC 60947-7-1 |
| Maximum load current | 232 A (with 95 mm ² conductor cross section) |
| Nominal current I _N | 232 A |
| Nominal voltage U _N | 1500 V |
| Maximum load current | 232 A (with 95 mm ² conductor cross section) |
| Open side panel | nein |
| Shock protection test specification | DIN EN 50274 (VDE 0660-514):2002-11 |
| Back of the hand protection | guaranteed |
| Finger protection | guaranteed |
| Surge voltage test setpoint | 9.8 kV |
| Result of surge voltage test | Test passed |
| Result of power-frequency withstand voltage test | Test passed |
| Checking the mechanical stability of terminal points (5 x conductor connection) | Test passed |
| Bending test rotation speed | 10 rpm |
| Bending test turns | 135 |
| Bending test conductor cross section/weight | 25 mm ² / 4.5 kg |
| | 95 mm ² /14 kg |
| Result of bending test | Test passed |
| Conductor cross section tensile test | 25 mm ² |
| Tractive force setpoint | 135 N |
| Conductor cross section tensile test | 95 mm ² |
| Tractive force setpoint | 351 N |
| Tensile test result | Test passed |
| Setpoint | 15 N |
| Result of tight fit test | Test passed |
| Requirements, voltage drop | ≤ 3.2 mV |
| Result of voltage drop test | Test passed |
| Temperature-rise test | Test passed |
| Conductor cross section short circuit testing | 95 mm ² |
| Short-time current | 11.4 kA |
| Short circuit stability result | Test passed |

High-current terminal block - PTPOWER 95-F - 3260133

Technical data

General

| | |
|---|--|
| Ageing test for screwless modular terminal block temperature cycles | 192 |
| Result of aging test | Test passed |
| Proof of thermal characteristics (needle flame) effective duration | 30 s |
| Result of thermal test | Test passed |
| Test specification, oscillation, broadband noise | DIN EN 50155 (VDE 0115-200):2008-03 |
| Test spectrum | Service life test category 2, bogie mounted |
| Test frequency | $f_1 = 5 \text{ Hz}$ to $f_2 = 250 \text{ Hz}$ |
| ASD level | $6.12 \text{ (m/s}^2\text{)}^2\text{/Hz}$ |
| Acceleration | 3.12 g |
| Test duration per axis | 5 h |
| Test directions | X-, Y- and Z-axis |
| Oscillation, broadband noise test result | Test passed |
| Test specification, shock test | DIN EN 50155 (VDE 0115-200):2008-03 |
| Shock form | Half-sine |
| Acceleration | 30g |
| Shock duration | 18 ms |
| Number of shocks per direction | 3 |
| Test directions | X-, Y- and Z-axis (pos. and neg.) |
| Shock test result | Test passed |
| Temperature index, insulating material (DIN EN 60216-1 (VDE 0304-21)) | 125 °C |
| Static insulating material application in cold | -60 °C |

Dimensions

| | |
|--------------------|-----------|
| Width | 25 mm |
| Length | 139.1 mm |
| Height | 99.8 mm |
| Hole diameter | 8 mm |
| Drill hole spacing | 126.40 mm |

Connection data

| | |
|--|--------------------|
| Connection in acc. with standard | IEC 60947-7-1 |
| Connection method | Push-in connection |
| Conductor cross section solid min. | 25 mm ² |
| Conductor cross section solid max. | 95 mm ² |
| Conductor cross section AWG/kcmil min. | 4 |
| Conductor cross section AWG/kcmil max | 3/0 |
| Conductor cross section stranded min. | 25 mm ² |
| Conductor cross section stranded max. | 95 mm ² |

High-current terminal block - PTPOWER 95-F - 3260133

Technical data

Connection data

| | |
|--|--------------------|
| Min. AWG conductor cross section, stranded | 4 |
| Max. AWG conductor cross section, stranded | 4/0 |
| Conductor cross section stranded, with ferrule without plastic sleeve min. | 25 mm ² |
| Conductor cross section stranded, with ferrule without plastic sleeve max. | 95 mm ² |
| Conductor cross section stranded, with ferrule with plastic sleeve min. | 25 mm ² |
| Conductor cross section stranded, with ferrule with plastic sleeve max. | 95 mm ² |
| Cross section with insertion bridge, solid max. | 95 mm ² |
| Cross section with insertion bridge, stranded max. | 70 mm ² |
| Cross section with insertion bridge, solid max. | 95 mm ² |
| Cross section with insertion bridge, stranded max. | 70 mm ² |
| Stripping length | 40 mm |

Classifications

eCl@ss

| | |
|------------|----------|
| eCl@ss 4.0 | 27141120 |
| eCl@ss 4.1 | 27141120 |
| eCl@ss 5.0 | 27141120 |
| eCl@ss 5.1 | 27141120 |
| eCl@ss 6.0 | 27141120 |
| eCl@ss 7.0 | 27141120 |
| eCl@ss 8.0 | 27141120 |

ETIM

| | |
|----------|----------|
| ETIM 3.0 | EC000897 |
| ETIM 4.0 | EC000897 |
| ETIM 5.0 | EC000897 |

UNSPSC

| | |
|---------------|----------|
| UNSPSC 6.01 | 30211811 |
| UNSPSC 7.0901 | 39121410 |
| UNSPSC 11 | 39121410 |
| UNSPSC 12.01 | 39121410 |
| UNSPSC 13.2 | 39121410 |

Approvals

Approvals

High-current terminal block - PTPOWER 95-F - 3260133

Approvals

Approvals


UL Recognized / cUL Recognized / EAC / cULus Recognized


Ex Approvals

IECEX / ATEX / EAC Ex


Approvals submitted

Approval details

| | |
|---|--------|
| UL Recognized  | |
| mm ² /AWG/kcmil | 4-4/0 |
| Nominal current I _N | 230 A |
| Nominal voltage U _N | 1000 V |

| | |
|--|--------|
| cUL Recognized  | |
| | C |
| mm ² /AWG/kcmil | 4-4/0 |
| Nominal current I _N | 230 A |
| Nominal voltage U _N | 1000 V |

| |
|-----|
| EAC |
|-----|

| |
|--|
| cULus Recognized  |
|--|

Drawings

High-current terminal block - PTPOWER 95-F - 3260133

Circuit diagram



Dimensioned drawing

